

Certificate of Compliance

Certificate Number 20091118-EX6296
Report Reference 2009 November 18
Issue Date 2009 November 18

Page 1 of 2



**Underwriters
Laboratories Inc.®**

Issued to: **FIRE SERVICE PLUS INC.**

PMB 424
180 Etowah Trace
Fayetteville, GA 30214

*This is to certify that
representative samples of*

Wetting Agents:

FireAde 2000 wetting agent concentrate when added to water in concentrations of not less than 0.25% for Class A fires and not less than 0.5% for Class B fires.


Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

The basic standard used to investigate products in this category is:
ANSI/NFPA 18 (2006), "Wetting Agents."

Additional Information: See addendum page 1

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:

Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:

Monica Westphal

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.